Type Test Report

[redacted]

"1+" or "3"

Notification No.: 1008

Test Report No.: 28240340.001 **Order No.:** 93356030 **Page** 1 / 3

[redacted]

Harmonised standard: EN 50575:2014 + A1:2016
Classification standard: EN 13501-6:2014

Throughout this report a comma is used as the decimal separator.

Abbreviations: ***ok / P*** = ***passed***
fail / F = ***failed***
n.a. / N/A = ***not applicable***
data / D = ***ublication of data***

This test report relates to the a_m test item. Without permission of the test center this test report is not permitted to be

www.tuv.hu

EN 60332-1-2

Clause	Requirement + Test	Result - Remark	Verdict
	ZTT GYFJH-2F 7.0mm (ZTT 0959)		
5	**Procedure**		
	Sample lenght (600 ± 25 mm)....:	615	P
	Approx. outer diameter (mm) :	7.0	
6	**Evaulation of test results**		
	Not damaged area from lower edge of the top support (min. 50 mm).....	366	P
	Damaged area from lower edge of the top support	498	P

No. of samples: 1

Ambient temperature: 26,5 °C

Date of test: 2017.09.07

Photo documentation

Before test

After test

Measurin e ui ment list

Device	Manufacturer	Type	Identification No.	Next calibration
Measuring tape	Stabila	BM 30W	503509	2019.09.21.
Stop-watch	Helvetia	S001	502911	2017.10.25.
Digital caliper	Mitutoyo	CD-15B	0556014003	2018.01.03.

-END OF TEST REPORT-